

Effective Immediately!!!

Smoke Detector Requirements Have Changed!!!!

If you are selling your home or renting please read the updated changes to the Fire Code

All battery smoke detectors must be the 10 year sealed battery units. No other detectors other than those listed below will be approved. § 5:70-4.19 Smoke alarms for one- and two-family dwellings; carbon monoxide alarms; and portable fire extinguishers

(a) In one- and two-family or attached single family dwellings subject to the requirements of N.J.A.C. 5:70-2.3, smoke alarms shall be installed as follows:

1. On each level of the premises; and 2. Outside of each separate sleeping area.

(b) The smoke alarms required in (a) above shall be located and maintained in accordance with NFPA 72. 1. The alarms shall not be required to be interconnected.

(c) Ten-year sealed battery-powered single station smoke alarms shall be installed and shall be listed in accordance with ANSI/UL 217, incorporated herein by reference. However, A/C-powered single or multiple-station smoke alarms installed as part of the original construction or rehabilitation project shall not be replaced with battery-powered smoke alarms. The effective date of this subsection shall be January 1, 2019. 1. A/C-powered smoke alarms shall be accepted as meeting the requirements of this section.

(d) Carbon monoxide alarms shall be installed in all dwelling units in buildings in one- and two-family or attached single family dwellings, except for units in buildings that do not contain a fuel-burning device or have an attached garage, as follows: 1. Single station carbon monoxide alarms shall be installed and maintained in the immediate vicinity of the sleeping area(s). 2. Carbon monoxide alarms may be battery-operated, hard-wired or of the plug-in type and shall be listed and labeled in accordance with UL-2034 and shall be installed in accordance with the requirements of this section and NFPA-720.

(e) A portable fire extinguisher shall be installed in accordance with the following: 1. The extinguisher shall be within 10 feet of the kitchen and located in the path of egress; 2. The extinguisher shall be readily accessible and not obstructed from view; 3. The extinguisher shall be mounted using the manufacturer's hanging bracket so the operating instructions are clearly visible; 4. The extinguisher shall be an approved listed and labeled type with a minimum rating of 2A-10B:C and no more than 10 pounds; 5. The owner's manual or written operation instructions shall be provided during the inspection and left for the new occupant; 6. The extinguisher shall be serviced and tagged by a certified Division of Fire Safety contractor within the past 12 months or the seller must have a receipt for a recently purchased extinguisher; and 7. The top of the extinguisher shall not be more than five feet above the floor Any questions please contact the Fire Prevention Bureau

**BOROUGH OF RUMSON
BOROUGH OF FAIR HAVEN**

Bureau of Fire Prevention
80 East River Road
Rumson, New Jersey 07760
732-842-3022 Office
732-842-0961 Fax

Email: mmarra@rumsonnj.gov

Kitchen Fire Extinguisher Type 2A:10-B:C



**Requirements for the type and placement of a portable fire extinguisher:
As of November 15, 2005**

1. At least one portable fire extinguisher shall be installed in all one and two family dwellings upon change of occupancy.
2. The extinguisher shall be listed, labeled, charged, and operable.
3. The size shall be no smaller than 2A:10-B:C, rated for residential use and weigh no more than 10 lbs.
4. The hangers or brackets supplied by the manufacturer must be used.
5. The extinguisher must be within 10 feet of the kitchen.
6. The top of the extinguisher must not be more that 5 feet above the floor.
7. The extinguisher must be visible and in a readily accessible location, free from being blocked by furniture, storage, or other items.
8. The extinguisher must be near a room exit or travel path that provides and escape route to the exterior.
9. The extinguisher must be accompanied by an owner's manual or written information regarding the operation, inspection, and maintenance of the extinguisher.
10. The extinguisher must be installed with the operating instructions clearly visible.